Classification Report



BASEC Client	Caleb Cable Industrial Limited
Report No.	KCPR1082 Classification Issue 2 Number of pages in this Report: 6
Issue Date	28 February 2017

Items Tested	6 samples of co-axial cables			
Specification(s)	BS EN 13501-6:2014			

Authorised by:	l McGuinness	funan	Laboratory Manager
Issue Date:	28 February 2017		
	•		be approval or certification of the product. This except in full, without written approval of the

British Approvals Service for Cables Presley House Presley Way Crownhill Milton Keynes MK8 0ES UK T: 01908 267300 F: 01908 267255 E: mail@basec.org.uk W: www.basec.org.uk

laboratory.



Notified Body No. 2661

Introduction

This classification report defines the classification assigned to the product, co-axial cables, in accordance with the procedures given in BS EN 13501-6:2014



CLASSIFICATION OF REACTION TO FIRE FOR ELECTRIC CABLES IN ACCORDANCE WITH BS EN 13501-6:2014

Sponsor:	Caleb Cable Industrial Limited
Prepared for:	Caleb Cable Industrial Limited
Place of Manufacture:	107 Luyuan Road, Ke Yuan Cheng, Tangxia, Dongguan, China
Prepared by:	British Approvals Service for Cables, Presley House, Presley Way, Crownhill
	Milton Keynes, MK8 0ES, United Kingdom
Notified Body No.	2661
Classification Report No.	KCPR1082 Classification Issue 2
Issue number:	2
Date of issue:	28 February 2017

This classification report consists of 6 pages and may only be used or reproduced in its entirety.

BASEC Reference: LF189.002		
issue date 12/07/2016	Report Issue Date: 28/02/2017	Page 2 of 6
1330e date 12/07/2010		

Details of classified product

General

This classification report defines the classification for the co-axial cables in accordance with the procedures given in BS EN 13501-6:2014.

Product description

The co-axial cables are as described in Sample details below.

Traceability

The test samples submitted by the manufacturer and received on 18 October 2016.

Sample details

Parameter	Details
Test sponsor	Caleb Cable Industrial Limited
Manufacturer of sample	Caleb Cable Industrial Limited
Place of manufacture	107 Luyuan Road, Ke Yuan Cheng, Tangxia, Dongguan, China
Cables submitted for test	
CC61/63/65 PVC/LSF	22 AWG copper conductor, PE insulation, metallic foil, wire braid, PVC/LSF jacket: 4.5mm OD
CC125 PVC/LSF	16 AWG copper conductor, PE insulation, metallic foil, wire braid, PVC/LSF jacket: 7.9mm OD
CC65 PVC/LSF Dual	2x (22 AWG copper conductor, PE insulation, metallic foil, wire braid, PVC/LSF jacket): 9.5mm x 4.6mm OD
CC100 PVC/LSF Dual	2x (18 AWG copper conductor, PE insulation, metallic foil, wire braid, PVC/LSF jacket): 13.5mm x 6.6mm OD
CC80 LSZH	20 AWG copper conductor, PE insulation, metallic foil, wire braid, LSZH jacket: 5.0mm OD
CC113 LSZH	17 AWG copper conductor, PE insulation, metallic foil, wire braid, LSZH jacket: 6.8mm OD

Italicised text is information supplied by the sponsor

BASEC Reference: LF189.002	D	
issue date 12/07/2016	Report Issue Date: 28/02/2017	Page 3 of 6

Reports & results in support of this classification

Reports

Name of Laboratory	Name of test sponsor	Test reports Nos.	Test method/field of application rules
BASEC	Caleb Cable Industrial Limited	KCPR1082	BS EN 60332-1-2:2004 + A1:2015

Results

		No.	Results			
Cable	Parameter	tests runs	Continuous parameter	Compliance with parameters Criterion for Class Eca		
CC61/63/65 PVC/LSF	н	1	87mm	≤ 425mm / Compliant		
CC125 PVC/LSF	н	1	92mm	≤ 425mm / Compliant		
CC65 PVC/LSF Dual	н	1	156mm	≤ 425mm / Compliant		
CC100 PVC/LSF Dual	н	1	225mm	≤ 425mm / Compliant		
CC80 LSZH	Н	1	108mm	≤ 425mm / Compliant		
CC113 LSZH	н	1	106mm	≤ 425mm / Compliant		

BASEC Reference: LF189.002	Report Issue Date: 28/02/2017	Page 4 of 6
issue date 12/07/2016		

Classification and field of application

Reference of classification

This classification has been carried out in accordance with BS EN 13501-6:2014

Classification

The co-axial cables in relation to reaction to fire behaviour are classified:

E_{ca}

The format of the reaction to fire classification for electric cables is:

Fire Behaviour		Smoke Pr	oduction		Flaming	Droplets		Aci	dity
E _{ca}	-	-	-	,	-	-	,	-	-

Reaction to fire classification: E_{ca}

The classification assigned to the products in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of samples tested.

BASEC Reference: LF189.002	Report Issue Date: 28/02/2017	Daga E of C
issue date 12/07/2016	Report Issue Date: 28/02/2017	Page 5 of 6

Field of application

This classification is valid for the co-axial cables described in 'Sample details' and listed below

Cable Identification	Reaction to Fire Classification
CC61/63/65 PVC/LSF	E _{ca}
CC80 PVC/LSF	E _{ca}
CC100 (RG6) PVC/LSF	E _{ca}
CC113 PVC/LSF	E _{ca}
CC125 PVC/LSF	E _{ca}
CC65 PVC/LSF Dual	E _{ca}
CC100 PVC/LSF Dual	E _{ca}
CC80 LSZH	E _{ca}
CC100 (RG6) LSZH	E _{ca}
CC113 LSZH	E _{ca}

This classification is valid for all end-use applications

Limitations

This classification will be valid whilst;

- The test methods remain unchanged,
- The product standard or technical approval remains unchanged,
- Constructional or material modifications do not exceed limits of the field of application.

The manufacturer has made a declaration, which is held on file, which the product placed in the marketplace, named in product description section of this report and produced at the manufacturing plant listed therein, is exactly the same as the product that was tested.

This classification document does not represent type approval or certification of the product.

- - END OF REPORT - - -

BASEC Reference: LF189.002	Report Issue Date: 28/02/2017	Dago 6 of 6
issue date 12/07/2016	Report Issue Date: 28/02/2017	Page 6 of 6