Classification Report



BASEC Client Caleb Cable Industrial Limited

Report No. KCPR1073 Classification Issue 3

Number of pages in this Report: 6

Issue Date 5 June 2017

Items Tested 1 sample of copper communication cable

Specification(s) BS EN 13501-6:2014

Authorised by: I McGuinness Laboratory Manager

Issue Date: 5 June 2017

This Classification Report does not represent type approval or certification of the product. This Classification Report shall not be reproduced except in full, without written approval of

the laboratory.

British Approvals Service for Cables

Presley House

Presley Way

Crownhill

Milton Keynes

MK8 0ES UK

T: 01908 267300

F: 01908 267255

E: mail@basec.org.uk W: www.basec.org.uk







5950

Notified Body No. 2661

Introduction

This classification report defines the classification assigned to the product, a copper communication cable, in accordance with the procedures given in BS EN 13501-6:2014



CLASSIFICATION OF REACTION TO FIRE FOR ELECTRIC CABLES IN ACCORDANCE WITH BS EN 13501-6:2014

Sponsor: Caleb Cable Industrial Limited
Prepared for: Caleb Cable Industrial Limited

Place of Manufacture: 107 Luyuan Road, Ke Yuan Cheng, Tangxia, Dongguan, China

Prepared by: British Approvals Service for Cables, Presley House, Presley Way, Crownhill

Milton Keynes, MK8 0ES, United Kingdom

Notified Body No. 2661

Classification Report No. KCPR1073 Classification – Issue 3

Issue number: 3

Date of issue: 5 June 2017

This classification report consists of 6 pages and may only be used or reproduced in its entirety.

BASEC Reference: LF189.002 | Report Issue Date: 05/06/17 | Page 2 of 6

Details of classified product

General

This classification report defines the classification for the copper communication cable in accordance with the procedures given in BS EN 13501-6:2014.

Product description

The copper communication cable is as described in Sample details below.

Traceability

The test samples submitted by the manufacturer and received on 21 September 2016.

Sample details

Parameter	Details	
Test sponsor	Caleb Cable Industrial Limited	
Manufacturer of sample	Caleb Cable Industrial Limited	
Place of manufacture	107 Luyuan Road, Ke Yuan Cheng, Tangxia, Dongguan, China	
Cable submitted for test		
S-FTP Cat 6a/Cat 7/Cat 7a LSZH 23 AWG	4 pairs of PE insulated copper conductors, individual pair shield, overall wire braid screen, LSZH jacket: 7.4mm OD Product code CCSFTPCAT4P	

Reports & results in support of this classification

Reports

Name of Laboratory	Name of test sponsor	Test reports Nos.	Test method/field of application rules
BASEC	Caleb Cable Industrial	KCPR1073	BS EN 50399:2011 BS EN 60332-1-2:2004 + A1:2015
UL LLC	Limited	LCPR1313	BS-EN 60754-2:2014

Results

		No.	Results			
Test method & test number	Test method & test		Continuous parameter	Compliance with parameters		
	FS		3.31m	>2.0m / D _{ca} Compliant		
	THR _{1200s}	1	41.0MJ	≤ 70MJ/ D _{ca} Compliant		
	Peak HRR		295kW	≤ 400W / D _{ca} Compliant		
BS EN 50399:2011	FIGRA		842.4W/s	≤ 1300W/s / D _{ca} Compliant		
	TSP _{1200s}	1	67.5m²	≤ 400m² / s2 Compliant		
	Peak SPR		0.36m ² /s	≤ 1.50m²/s / s2 Compliant		
	Flaming droplets/particles	1	>10s	flaming drips >10s / d2 compliant		
BS EN 60332-1-2:2004 + A1:2015	Н	1	112mm	≤ 425mm / Compliant		
BS-EN 60754-2:2014	pH/conductivity	3	pH = 5.93* conductivity =1.98μS/mm*	pH = >4.3 and < 2.5μS/mm = a1 compliant		

^{*} Weighted average of all components tested

BASEC Reference: LF189.002	Papart Issua Datas 05/06/17	Dage 4 of 6
issue date 12/07/2016	Report Issue Date: 05/06/17	Page 4 of 6

Classification and field of application

Reference of classification

This classification has been carried out in accordance with BS EN 13501-6:2014

Classification

The copper communication cable in relation to reaction to fire behaviour is classified:

 $D_{\text{ca}} \\$

The additional classification in relation to smoke production is:

s2

The additional classification in relation to flaming droplets / particles is:

d2

The additional classification in relation to acidity is:

a1

The format of the reaction to fire classification for electric cables is:

Fire Behaviour		Smoke Pi	oduction		Flaming	Droplets		Aci	dity
D _{ca}	-	S	2	,	d	2	,	а	1

Reaction to Fire Classification: Dca-s2,d2,a1

The classification assigned to the products in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of samples tested.

BASEC Reference: LF189.002	Devent leave Date: 05/05/17	Page 5 of 6		
issue date 12/07/2016	Report Issue Date: 05/06/17	Page 5 of 6		

Field of application

This classification is valid for the copper communication cable described in 'Sample details' and listed below

Cable Identification	Product Code	Reaction to Fire Classification
S-FTP Cat 6a/Cat 7/Cat 7a LSZH 23 AWG	CCSFTPCAT74P	D _{ca} -s2,d2,a1

This classification is valid for all end-use applications

Limitations

This classification will be valid whilst;

- The test methods remain unchanged,
- The product standard or technical approval remains unchanged,
- Constructional or material modifications do not exceed limits of the field of application.

The manufacturer has made a declaration, which is held on file, which the product placed in the marketplace, named in product description section of this report and produced at the manufacturing plant listed therein, is exactly the same as the product that was tested.

This classification document does not represent type approval or certification of the product.

-- END OF REPORT ---

BASEC Reference: LF189.002 issue date 12/07/2016	Report Issue Date: 05/06/17	Page 6 of 6
---	-----------------------------	-------------